




EXPIRES: 1 JUNE 2020

BEAL Appraisal Certificate



The Classic Stone's Manufactured Stone Veneer Cladding System



Product

1.1 Classic Stone's Manufactured Stone Veneer Cladding System comprises weather resistant light-weight manufactured stone pieces adhered by way of a durable acrylic modified cement based adhesive to one of three types of substrate over either timber or lightweight steel framing. The substrates include fibre-cement sheet, concrete block, and concrete tilt-up slab. The fibre cement sheets are fixed to cavity battens according to the manufacturer's instructions and subject to the limitations described in this appraisal.

1.2 Framing must comply with the requirements of NZS 3604 for timber framing or NASH Standard for Residential and Low-rise Steel Framing, Parts 1 and 2, for lightweight steel framing.

Building Regulations

2.1 In the opinion of BEAL, the Classic Stone Veneer Cladding system, if designed, installed and maintained in accordance with the statements and conditions of this Appraisal Certificate, will meet the following provisions of the New Zealand Building Code:

2.2 B1 STRUCTURE

Performances B1.3.1 and B1.3.3. See paragraph 7.1

2.3 B2 DURABILITY

Performance B2.3.1(b). See paragraph 8.1

2.4 E2 EXTERNAL MOISTURE

Performance E2.3.2. See paragraphs 9.1

2.5 F2 HAZARDOUS BUILDING MATERIALS

Performance F2.3.1. The Classic Stone's Manufactured Stone Veneer Cladding System meets this requirement and will not present a health hazard to people. See paragraph 10.1

The Classic Stone Veneer Cladding system has been appraised as an Alternative Solution in terms of New Zealand Building Code Compliance.

Applicant:



Classic Stone

Classic Stone Ltd.

49 Elginshire St
 Timaru 7910
 Tel: 03 688 7036
 Fax: 03 688 7037
 E-Mail: info@classicstone.co.nz
 www.classicstone.co.nz

Appraiser:

**BEAL**

2A Plimmerton Drive
 Plimmerton, Porirua, NZ
 Tel: +64 233 6661
 E-Mail: sales@beal.co.nz
 www.beal.co.nz



The most up to date version of this BEAL Appraisal Certificate can be viewed at www.beal.co.nz

Scope and Limitations

3.1 The Classic Stone's Manufactured Stone Veneer Cladding System has been appraised for use as an external cladding system over timber framing or light gauge steel framing complying with the requirements of the New Zealand Building Code (NZBC) within the following scope:

- Scope limitations of NZBC Acceptable Solution E2/AS1, Paragraph 1.1, and;
- With a risk score of 0-20, calculated in accordance with NZBC Acceptable Solution E2/AS1, Table 2; and,
- Can be situated in up to and including 'Very High' wind zones as described in NZS 3604:2011 Building Wind Zones.
- Incorporating the use of cavity battens, and wall underlay that complies with the NZBC.

3.2 The wall system is appraised for use with aluminium window and door joinery for use in a rebated opening as shown in the Technical and Installation Manual. In each situation the specified rebates to the head, jambs and sill details must be complied with. The air seals are to be installed as shown in the relevant drawings. The performance of the Classic Stone's Manufactured Stone Veneer Cladding System relies on the window and door joinery meeting the performance requirements of NZS 4211 for the relevant Wind Zone or being specifically designed for use.

3.3 The cladding system shall be installed only by Classic Stone's Ltd. trained and approved applicators.

Technical Literature

4.1 The Classic Stone Technical and Installation Manual, and Detail Drawings describes the correct method of installation and must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained within the Technical Literature and scope of this Appraisal Certificate must be followed.

4.2 For a copy of this Technical Literature and any subsequent updates please refer to www.beal.co.nz

Technical Specification

5.1 Classic Stone's Manufactured Stone Veneer Cladding System is deemed a Medium Weight wall cladding based on NZS 3604, being 40 to 50 kg /m², comprising of approximately 20 - 45mm thick pieces of light-weight manufactured stone of varying sizes (a proprietary masonry product) glued on their back to the nominated substrate using a proprietary acrylic-modified sand and cement based adhesive. The adhesive is also used as the splash coat and grout between the pieces of manufactured stone to produce a weather resistant aesthetically attractive finish. In order to prevent moisture ingress past the face of the cladding system, two coats of **CS Water Repellent** is applied over the finished wall or column once the installation of the manufactured stones is complete.

5.2 This cladding system is described throughout this appraisal as 'the Classic Stone Cladding System'.

Handling and Storage

5.3 The Classic Stone manufactured stones are supplied loose in cardboard boxes, of varying sizes and can be stored indefinitely when kept dry and out of the weather.

5.4 The **CS Acrylic Stone** admixture is supplied in 5 and 20 litre plastic containers. The **CS graded sand** is supplied in 20 kg paper sacks. The cement complying with NZS 3122 is obtained from trade suppliers in 25 kg paper sacks.

All products shall be stored in a dry space out of the weather and in a manner to prevent accidental damage.

Design Information

General

6.1 The Classic Stone Technical and Installation Manual, and Detailed Drawings are designed to enable designers to understand the construction and installation details of the Classic Stone Cladding System.

Structure - Clause B1

7.1 The Classic Stone Cladding System when used in accordance with this Appraisal will meet Performance Requirements of B1.3.1, and B1.3.3 (a), (b), (f) and (h) of the NZBC.

Durability - Clause B2

8.1 The Classic Stone Cladding System when used in accordance with this Appraisal will meet Performance Requirement B2.3.1(b) of the NZBC.

In other words, the product as appraised will be durable for at least 15 years.

External Moisture - Clause E2

9.1 The Classic Stone Cladding System complies with performance clause E2.3.2 of the Building Code when installed in accordance with this Appraisal.

In other words, the product as appraised will "prevent the penetration of water that could cause undue dampness, or damage to building elements".

Hazardous Building Materials - Clause F2

10.1 The product contains no hazardous materials and complies with clause F2.3.1 of the Building Code.

Maintenance

11.1 The maintenance of the completed application of the Classic Stone Cladding System consists of annual inspection and, where necessary, cleaning and removal of contamination that could reduce the performance and/or life of the exterior finish.

11.2 In the event of damage to the exterior finish, the location and details along with photos shall be recorded with a copy supplied to the applicator company or Classic Stone Ltd. for action. No applicator may carry out repairs without the prior approval of Classic Stone Ltd.

Installation Information

Installation Skill Requirement

12.1 Installation of the Classic Stone Cladding System must be completed by Classic Stone Ltd. approved and trained applicators who have experience in the application of stone veneer products.



Health and Safety

13.1 Guidance for the safe use and handling of the components and related materials of the Classic Stone Cladding System is provided in the Technical Literature. The products must be used in conjunction with the relevant materials safety data sheet for each product.

Basis of Appraisal

BEAL use the compliance verification procedure to evaluate compliance with the relevant clauses of the NZBC including a risk analysis procedure. The following is a summary of the technical investigations carried out.

Assessments

14.1 The following assessments of the Classic Stone Cladding System have been undertaken by BEAL: Review of structural data test and Technical Literature supplied by Classic Stone Ltd.

Tests

15.1 The following testing of the Classic Stone Cladding System has been undertaken by BEAL to verify compliance:

- Weathertightness by way of testing using a method adapted for thermal mass walls based on E2/MM1.

Other Investigations

16.1 The ability of the Classic Stone Cladding System to support self weight and wind loadings, was assessed by an independent engineer.

16.2 An opinion has been given by BEAL of the durability of The Classic Stone Cladding System based on other Technical Literature and in-service history.

16.3 The Classic Stone Cladding System was also evaluated (including site visits) in practical building situations assessing the following:

- Ease of installation;
- Potential risks of non-performance when being installed;
- Any external factors that could affect the quality of the installed product;
- Ease of repair or maintenance.

16.4 The Technical Literature has been examined by BEAL and found to be satisfactory.

Quality

17.1 The manufacture of the Classic Stone Cladding System has not been assessed by BEAL, but details regarding the quality and composition of the materials used were obtained by BEAL and found to be satisfactory.

17.2 The quality of materials, components and accessories supplied by Classic Stone Ltd. is managed through the use of a Building Product Quality Plan.

17.3 The Classic Stone Ltd. Building Product Quality Plan ensures continuous conformance with the quality requirements from purchase to supply of components.

17.4 Classic Stone Ltd's Building Product Quality Plan is reviewed and audited at least annually by BEAL or appointed agent.

17.5 Designers are responsible for the substructure design, and building contractors are responsible for the quality of construction of the substructure or new substrate in accordance with the instructions of the substrate

manufacturer and this Appraisal Certificate.

17.6 Building owners are responsible for the maintenance of the Classic Stone Cladding System in accordance with the instructions of Classic Stone Ltd. and this Appraisal Certificate.

Sources of Information

- New Zealand Building Code
- Acceptable Solutions E2/AS1
- AS/NZS 1170:2002 Structural Design Actions
- AS/NZS 4284:2008 Testing of Building Facades
- NZS 3122:2009 Specification for Portland and Blended Cements
- NZS 4211:2008 Specification for Performance of Windows
- NZS 3604:2011 Timber-framed buildings
- NASH Standard Residential and Low-rise Steel Framing, Parts 1 and 2
- BEAL test Reports

Concluding statement

18.1 In the opinion of BEAL, the Classic Stone Cladding System is fit for purpose and will comply with the NZBC to the extent specified provided that it is used, designed, installed and maintained as set out in this Appraisal Certificate.

18.2 The Appraisal Certificate is issued only to Classic Stone Ltd. and is valid until the expiry date on the front of this appraisal certificate.

Conditions of Appraisal

1. This appraisal Certificate :
 - a) Relates only to the Classic Stone Cladding System as described herein;
 - b) Must be read, considered and used in full, together with the current version of the Technical Literature;
 - c) Does not address any legislation, regulations, codes or standards, not specifically named herein;
 - d) Is copyright of BEAL.
2. The Appraisal Certificate holder continues to meet the quality requirements of the Classic Stone Ltd. Building Product Quality Plan and has the plan audited and Appraisal certificate revalidated by BEAL on an annual basis.
3. Classic Stone Ltd. shall notify BEAL and obtain approval of any changes of the product specification or quality assurance prior to product being marketed, including any trade literature, web site info or the like.
4. BEAL makes no representation as to:
 - a) The nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) The presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) Any guarantee or warranty offered by the Appraisal Certificate holder.
5. BEAL's verification of the building product or system complying with one or more of the above-mentioned criteria is given on the basis that the criteria used were those that were appropriate to demonstrate compliance with the NZBC at the date of this Appraisal Certificate. In the event that the criteria is withdrawn or amended at a later date, this Appraisal may no longer remain valid.
6. Any reference in this Appraisal Certificate to any other publication shall be read as a reference to the version of publication specified in this Appraisal Certificate.

Authorised Signatory



C R Prouse - Manager
BEAL Testing Services
[Updated August 2017]

