



# CERTIFICATE OF CONFORMITY

This is to certify that

## The Nuraply 3PT Waterproof Tanking Membrane system



[www.jas-anz.org/register](http://www.jas-anz.org/register)

### Product description

The Nuraply 3PT Waterproof Tanking Membrane system is a single layer torch-on modified bitumen sheet membrane system for below grade waterproofing. The system covers the products Nuraply 3PT, Nuraply 3PTM and Nuraply 3PG. A weather resistant capsheet is heat adhered where exposed to UV.

### Product purpose or use

Nuraply 3PT Waterproof Tanking Membrane system is intended for use on below grade walls, protected from impact with an approved protection system, and beneath floor slabs on compacted hard-fill. The product is typically used for waterproofing walls above and below grade onto the following substrates; concrete substrates complying to NZS 3101 (2006) and concrete block surfaces NZS 4229 (2013).

### Certificate Holder

**Nuralite Waterproofing Ltd.**  
53A Victoria Street  
Onehunga Auckland 1061.  
Phone 09 579 2046  
[www.nuralite.co.nz](http://www.nuralite.co.nz)

### CodeMark Certification Body

BEAL Certification Service Limited  
2A Plimmerton Drive  
Plimmerton, Porirua 5026, NZ  
Phone: +64 4 233 6661  
[bcs@beal.co.nz](mailto:bcs@beal.co.nz)  
Website: [www.beal.co.nz](http://www.beal.co.nz)

### Complies with the New Zealand Building Code:

Performance Clauses B1.3.2 and B1.3.3 (b) & (e)  
Performance Clauses B2.3.1 (a) and B2.3.2 (a)  
Performance Clause E2.3.2 and E2.3.3  
Performance Clause F2.3.1.

Compliance with other clauses have been considered and found not applicable.

### Subject to the following:

#### Limitations of use -

- A. All designs and construction shall be within the requirements and the tables set out in the Nuraply 3PT Waterproof Tanking Membrane Installation Manual (2016 edition 4) available from the manufacturer's web site [www.nuralite.co.nz](http://www.nuralite.co.nz); and, all other uses are outside the scope of this certificate. Designed for walls and floor slabs to support natural ground free of contaminants and with a drainage system provided to walls. Where vegetation roots may exist 3PG root -inhibited membrane shall be used.
- B. Accessories, componentry, cladding and finishing systems to comply with that specified in the Nuraply 3PT Waterproof tanking membrane Installation Manual (2016 edition 4) and the Nuraply Waterproofing Membrane Building Product Quality Plan (2015 -v1);
- C. Installation shall be performed by Nuralite Waterproofing Ltd trained and approved installers, who shall be supervised by a suitably qualified Licensed Building Practitioner;
- D. Installation and maintenance - where required - of the Nuraply 3PT Waterproof tanking membrane shall be in accordance with the Nuraply Building Product Quality Plan, available on request;


#### Conditions of certification -

- E. The Building Product Quality Plan for the Nuraply 3PT Waterproof Tanking Membrane Installation Manual (2016 edition 4) shall be reviewed and subject to audit at their head office and building sites by the issuer at least once a year;
- F. This CodeMark Certificate shall be revalidated on an annual basis;
- G. This CodeMark Certificate is subject to S15 of the Building Product Certification Regulations 2008.

### Technical information:

Information that forms part of this certificate or the basis for certification is available from the issuer on request and may be subject to a fee.

**Note that this certificate may only be reproduced in its entirety.**

  
**C R Prouse**  
Director  
BEAL Certification Service

9 Aug 2016

Date of issue

BCS143316-CMNZ

Certificate Number